

IEC 61850 Certificate - IEC 61850 Certificate #7022

RD55UP12-V Intelligent Function Module with iQ-R R32PCPU CPU Module

10/09/2024 07:49 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 24-4291_DNV_ME-Automation_RD55_ClientEd2_Certificate.pdf
61850 Tested Aspects:	Client	Certificate Hash: SHA256: 5DB374FA779269576985CA92C308F0 E080275660DAE038F501E7F76CADFD 05C3
Company:	Mitsubishi Electric Corporation Nagoya Works	Vendor Artifact File Name:
Address:	1-14 Yada-Minami 5-chome Higashi-ku Nagoya 461-8670 Japan	Vendor Artifact Hash:
Product:	RD55UP12-V Intelligent Function Module with iQ-R R32PCPU CPU Module	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	1.4.0	Serial Number: 01017821F1210101-5
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	1.2	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	10/09/2024	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:	Edition 2 Client Test Procedures version 1.2	Time Activated Control:
Description Intelligent Function Module with CPU Module		

Files

24-4291_DNV_ME-Automation_RD55_ClientEd2_Certificate.pdf	105 KB	10/09/2024	Herbert Falk
--	--------	------------	--------------