

Client - Issues #7029

cFtN3 step 2: SetFile has no Ed1 specific error code

10/18/2024 04:35 AM - Richard Schimmel

Status: Priority: Assignee: Category: Target version: Discuss in Upcoming Meeting: Clause Reference: 61850 Standard: Triggering Tissue: Final Decision: Initial Test Document:	Resolved Normal Richard Schimmel No 8-1 TP1.0	Due date: Updated Test Document: Test Case ID: Closed Reason: Triggering Tissue 2: Triggering Tissue 3:
Description Same as for cSrvN10 and cLogN5 the SetFile has no Ed1 specific error code. I propose to remove cFtN3 step 2 (step 1 is OK).		

History

#1 - 10/29/2024 09:03 AM - IEC 61850 TPWG

- Status changed from New to Resolved
- Assignee set to Richard Schimmel

Accepted