

IEC 61850 Certificate - IEC 61850 Certificate #7037

PWC600

10/28/2024 07:36 AM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2 Amd 1	Certificate Name:	24-4136_DNV_Hitachi_Energy_PWC600_ServerEd2Amd1_Certificate.pdf
61850 Tested Aspects:	Server	Certificate Hash:	24-4136_DNV_Hitachi_Energy_PWC600_ServerEd2Amd1_Certificate.pdf
Company:	Hitachi Energy Sweden AB	Vendor Artifact File Name:	
Address:	SE-721 59 Västerås Sweden	Vendor Artifact Hash:	
Product:	PWC600	Umbrella Organization:	
HW Version:	3.0.1	Optional Reservation Test:	Yes
SW Version:	0.6.17.284	Serial Number:	
Key Words:		Publisher Legacy Variants:	-
Test Procedure Version:	1.2	Publisher Preferred Rates:	-
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Data Sets (B2), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Substitution (B3), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Publisher Preferred Variants:	T2344095
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants:	-
Approval Date:	10/28/2024	Subscriber Preferred Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:	-
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:	
Test Document:	Edition 2 with Amendment 1 Server Test Procedures version 1.2	Time Activated Control:	
Description Point-on-Wave Controller IED			
Related issues: Copied to IEC 61850 Certificate - IEC 61850 Certificate #7038: PWC600 Approved			

History

#1 - 10/28/2024 07:43 AM - Herbert Falk

- IEC 61850 Blocks Certified Basic Exchange (B1a), Data Sets (B2), Setting Group (B4), Substitution (B3) added

#2 - 10/28/2024 07:45 AM - Herbert Falk

- Copied to IEC 61850 Certificate #7038: PWC600 added

Files

24-4136_DNV_Hitachi_Energy_PWC600_ServerEd2Amd1_Certificate.pdf 967 KB

10/28/2024

Herbert Falk