

61850-7-5 and 61850-7-500 - IEC61850-7-5 #7045

Position state to be published after expiration of the timeout of the suppression of the intermediate position

10/30/2024 06:13 AM - Michael Haecker

Status:	New	Start date:	10/30/2024
Priority:	Normal	Due date:	
Assignee:		% Done:	0%
Category:			
Target version:			
Source:		TF 7-5 Project document:	-
Category:	Not yet categorized	Related TISSUE:	
Description			
IEC/TR 61850-7-5 clause 5.2.3 states that the 'bad' state can be set for 'Pos.stVal' after the expiration of the supervision time.			
Preliminary answer: to be modified to "intermediate" state or - more general - to the state delivered from process level.			