

IEC 61850 Certificate - IEC 61850 Certificate #7049

CSI-200E-ER

11/04/2024 07:56 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2 Amd 1	Certificate Name: 24-4316_DNV_Beijing Sifang_CSI-200E-ER_clientEd2Amd1_Certificate.pdf
61850 Tested Aspects:	Server	Certificate Hash: SHA256: C8DF374D46867E918E544A1E4BBFD59E3E704E737584C53F80F2B74B71F08F71
Company:	Beijing Sifang Automation Co., Ltd.	Vendor Artifact File Name:
Address:	No.9, Shangdi 4th Street, Haidian District 100085, Beijing China	Vendor Artifact Hash:
Product:	CSI-200E-ER	Umbrella Organization:
HW Version:		Optional Reservation Test: Yes
SW Version:	1.0.1	Serial Number: SFJB 400009622124000001
Key Words:	RTU	Publisher Legacy Variants: -
Test Procedure Version:	1.0	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), Logging (B7), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	11/04/2024	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:	Edition 2 with Amendment 1 Client Test Procedures version 1.0	Time Activated Control:
Description		

Files

24-4316_DNV_Beijing Sifang_CSI-200E-ER_clientEd2Amd1_Certificate.pdf	11/04/2024	Herbert Falk
--	------------	--------------