

IEC 61850 Certificate - IEC 61850 Certificate #7050

SN-SMD-V01

11/04/2024 08:39 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2 Amd 1	Certificate Name: 24-059080-04-2_SANION_SN-SMD-V01_Server_Ed2.1_Certification_KTL.pdf
61850 Tested Aspects:	Server	Certificate Hash: SHA256: E0DF685976D9CF7D3CDA5517127C49 115E47D86C2DE6246CCE10C087F41E 73CD
Company:	SANION	Vendor Artifact File Name:
Address:	13,Geomdan-ro 114 beon-gil, Seo-gu,Incheon 22663,Rep. of KOREA	Vendor Artifact Hash:
Product:	SN-SMD-V01	Umbrella Organization:
HW Version:	1.0	Optional Reservation Test: Yes
SW Version:	1.0	Serial Number: SN-SMD-V01-2024-9001
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	1.2	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	11/04/2024	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	Korea Testing Laboratory (A)	Product Variants:
Test Document:	Edition 2 with Amendment 1 Server Test Procedures version 1.2	Time Activated Control:
Description Substation Automation Information Monitoring and diagnostic device		
Related issues: Copied to IEC 61850 Certificate - IEC 61850 Certificate #7051: SN-SMD-V01 Approved		

History

- #1 - 11/04/2024 08:41 AM - Herbert Falk
- Copied to IEC 61850 Certificate #7051: SN-SMD-V01 added
- #2 - 11/06/2024 07:34 AM - Herbert Falk
- 61850 Tested Aspects Server added

Files

24-059080-04-2_SANION_SN-SMD-V01_Server_Ed2.1_Certification_1270.ppt	11/04/2024	Herbert Falk
--	------------	--------------