

IEC 61850 Certificate - IEC 61850 Certificate #7053

GridSol IEC61850 Client

11/14/2024 12:51 PM - Herbert Falk

Status:	Approved	Certificate Name:	24-034241-01-1_LS ELECTRIC_GridSol SCADA_CMD_Smart-SWGR_Client_Ed 2_Certificate_KTL.pdf
Priority:	Normal	Certificate Hash:	SHA256: 8E3977167FCD4B7C37808EC8B18A5F 07959DFBBD3112AA7C45BBB6E8D7 205E8
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Client	Vendor Artifact Hash:	
Company:	LS ELECTRIC	Umbrella Organization:	
Address:	LS ELECTRIC, 127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do, Republic of Korea	Optional Reservation Test:	Yes
Product:	GridSol IEC61850 Client	Serial Number:	LS_GridSol_2.5
HW Version:	1.0	Publisher Legacy Variants:	-
SW Version:	2.5	Publisher Preferred Rates:	-
Key Words:		Publisher Preferred Variants:	
Test Procedure Version:	1.2	Subscriber Legacy Variants:	-
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Control Block (9), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Rates:	-
Approval Date:	11/14/2024	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Time Activated Control:	No
Current Test Lab Name:	Korea Testing Laboratory (A)		
Test Document:	Edition 2 Client Test Procedures version 1.2		
Description			
LG 15u50p: GridSol SCADA/CMD/Smart-SWGR			

Files

24-034241-01-1_LS ELECTRIC_GridSol SCADA_CMD_Smart-SWGR_Client_Ed2_Certificate_KTL.pdf

Herbert Falk