

IEC 61850 Certificate - IEC 61850 Certificate #7054

FTU-R300

11/14/2024 12:58 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2 Amd 1	Certificate Name: 24-032695-01-1_Certificate_PNCTech_I ED_FTU-R300_Ed2p1_Final
61850 Tested Aspects:	Server	Certificate Hash: SHA256: 428CD83F10922B33647FBB32B1C2C9 046709664E2F4D7DE86D07214E50AD 8D5C
Company:	PNC Technologies Co., Ltd.	Vendor Artifact File Name:
Address:	68, Gwacheon-daero 7-gil, Gwacheon-si, Gyeonggi-do, 13840, Republic of Korea	Vendor Artifact Hash:
Product:	FTU-R300	Umbrella Organization:
HW Version:	1.00	Optional Reservation Test: Yes
SW Version:	1.00	Serial Number: FTU-R300-2404-0002
Key Words:	RTU	Publisher Legacy Variants: -
Test Procedure Version:	1.2	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	11/14/2024	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	Korea Testing Laboratory (A)	Product Variants:
Test Document:	Edition 2 with Amendment 1 Server Test Procedures version 1.2	Time Activated Control: No
Description Feeder Terminal Unit		
Related issues: Copied to IEC 61850 Certificate - IEC 61850 Certificate #7055: FTU-R300 Approved		

History

- #1 - 11/14/2024 01:02 PM - Herbert Falk
- Copied to IEC 61850 Certificate #7055: FTU-R300 added

Files

24-032695-01-1_Certificate_PNCTech_IED_FTU-R300_Ed2p1_Final.pdf	164 KB	11/14/2024	Herbert Falk
---	--------	------------	--------------