

IEC 61850 Certificate - IEC 61850 Certificate #7061

SEL-3350

11/25/2024 06:52 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 24-4261_DNV_SEL_RTAC-3350_Server Ed2_Certificate.pdf
61850 Tested Aspects:	Server	Certificate Hash: SHA256: 45112466A41640460368B40F977E7DA 9606B0F736F6CB23CB9A1EAD99D5499B4
Company:	Schweitzer Engineering Laboratories, Inc.	Vendor Artifact File Name:
Address:	2350 NE Hopkins Court Pullman, WA 99163-5603 USA	Vendor Artifact Hash:
Product:	SEL-3350	Umbrella Organization:
HW Version:		Optional Reservation Test: Yes
SW Version:	SEL-3350-R150-V8-Z000303-D20240918	Serial Number: 1223191845
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	2.0.6	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	11/25/2024	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:	Edition 2 Server Test Procedure version 2.0.6	Time Activated Control: No
Description Real-Time Automation Controller		
Related issues: Related to IEC 61850 Certificate - IEC 61850 Certificate #7056: SEL-3350 Approved		

History

- #1 - 11/25/2024 06:53 PM - Herbert Falk
- Related to IEC 61850 Certificate #7056: SEL-3350 added

Files

24-4261_DNV_SEL_RTAC-3350_ServerEd2_Certificate.pdf	97.3 KB	11/26/2024	Herbert Falk
---	---------	------------	--------------