

IEC 61850 Certificate - IEC 61850 Certificate #7063

SA-OPD

11/27/2024 01:42 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2 Amd 1	Certificate Name: 24-045122-01-3_DongWoo_DWSA-OP_Client_Ed2.1_Certification_KTL.pdf
61850 Tested Aspects:	Client	Certificate Hash: SHA256: 524D81E65FD49534D07C9078A7BBB8 28CE97A35FAF085BD307B964D5767E F65F
Company:	DONGWOO ELECTRIC CORP	Vendor Artifact File Name:
Address:	34, Oseongseo-ro, Anjung-eup, Pyeongtaek-si, Gyeonggi-do, Republic of Korea, 17928	Vendor Artifact Hash:
Product:	DWSA-OP	Umbrella Organization:
HW Version:	1.0/ HP Z2 Tower G9 Workstation	Optional Reservation Test: Yes
SW Version:	1.0/ Windows Server 2019	Serial Number: DWSA-OP-2024-001
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	1.0	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Control Block (9), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	11/27/2024	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	Korea Testing Laboratory (A)	Product Variants:
Test Document:	Edition 2 with Amendment 1 Client Test Procedures version 1.0	Time Activated Control: No
Description Substation Automation Operation Processing Device		
Related issues: Copied to IEC 61850 Certificate - IEC 61850 Certificate #7064: SA-OPD		
		Approved

History

#1 - 11/27/2024 01:45 PM - Herbert Falk

Files

24-045122-01-3_DongWoo_DWSA-OP_Client_Ed2.1_Certification_KTL.pdf	90 KB	11/27/2024	Herbert Falk
---	-------	------------	--------------