

Server - Issues #7073

Reference to SICS I211

12/05/2024 03:36 AM - Hua Qin

<b>Status:</b> <b>Priority:</b> <b>Assignee:</b> <b>Category:</b> <b>Target version:</b> <b>Discuss in Upcoming Meeting:</b> <b>Clause Reference:</b> <b>61850 Standard:</b> <b>Triggering Tissue:</b> <b>Final Decision:</b> <b>Initial Test Document:</b>	Resolved Normal Richard Schimmel   No     ED2.1 Server TP Revision 1.3	<b>Due date:</b>     <b>Updated Test Document:</b> <b>Test Case ID:</b> <b>Closed Reason:</b> <b>Triggering Tissue 2:</b> <b>Triggering Tissue 3:</b>
<b>Description</b>  In the test procedure, SICS is used in several test cases. But the chapter 1.1 Identification does not refer to SICS  Suggest: 1 Update chapter 1.1 to put SICS for ICT into the identification table, add Annex to show the SICS ICT template  Extra discussion: 2: should we update certificate template to include the SICS information 3: should we update the certificate template to include the ICT version in the "For the sever product" part		

History

#1 - 12/05/2024 03:42 AM - Hua Qin

In the test procedure, SICS is used in several test cases.  
But the chapter 1.1 Identification does not refer to SICS

Suggest:  
1 Update chapter 1.1 to put SICS for ICT into the identification table, add Annex to show the SICS ICT template

Extra discussion:  
2: should we update test procedure chapter 5 and certificate template to include the SICS information  
3: should we update test procedure chapter 5 and certificate template "For the sever product" part to include the ICT version

#2 - 12/11/2024 03:27 AM - Hua Qin

- Subject changed from Reference to SICS is missing in TP1.3 to Reference to SICS I211

#3 - 01/20/2025 08:10 AM - Richard Schimmel

The testcases that refer to SICS have a workaround. The SICS is optional/is not required to perform the server test. I propose we mention the SICS in the test report when available (not on the certificate)

#4 - 01/21/2025 08:23 AM - IEC 61850 TPWG

Richard to add mention of the SICS in the test report when available.

sMdl23 to refer to PIXIT entry for I211 when SICS is not available.

#5 - 01/21/2025 08:30 AM - IEC 61850 TPWG

- Status changed from New to Resolved  
- Assignee set to Richard Schimmel