

Server - Issues #7074

Update chapter 1.1 identifications table to have SCT simulator information

12/05/2024 04:07 AM - Hua Qin

Status:	Resolved	Due date:	
Priority:	Normal		
Assignee:	Richard Schimmel		
Category:			
Target version:			
Discuss in Upcoming Meeting:	Yes	Updated Test Document:	
Clause Reference:	1.1	Test Case ID:	
61850 Standard:		Closed Reason:	--Not Set--
Triggering Tissue:		Triggering Tissue 2:	
Final Decision:		Triggering Tissue 3:	
Initial Test Document:	ED2.1 server TP Revision 1. 3		

Description

SCT simulator is used to generate SCD and configure the DUT but the SCT simulator information is missed in chapter 1.1 Identifications table

Suggest to update the table with extra row to have SCT simulator information, like name/version

History

#1 - 01/20/2025 08:11 AM - Richard Schimmel

Agree

#2 - 01/21/2025 08:14 AM - IEC 61850 TPWG

- Status changed from New to Resolved
- Assignee set to Richard Schimmel

Accepted.