

## Server - Issues #7084

### sTmP5 clarify the format of LTMS.TmSrc = GMCID

12/19/2024 04:57 AM - Richard Schimmel

<b>Status:</b> Resolved	<b>Due date:</b> 01/21/2025
<b>Priority:</b> Normal	
<b>Assignee:</b> Richard Schimmel	
<b>Category:</b>	
<b>Target version:</b>	
<b>Discuss in Upcoming Meeting:</b> No	<b>Updated Test Document:</b>
<b>Clause Reference:</b>	<b>Test Case ID:</b> sTmP5
<b>61850 Standard:</b> 7-2	<b>Closed Reason:</b> --Not Set--
<b>Triggering Tissue:</b> <a href="https://iec61850.tissue-db.com/tissues/1846">https://iec61850.tissue-db.com/tissues/1846</a>	<b>Triggering Tissue 2:</b>
<b>Final Decision:</b>	<b>Triggering Tissue 3:</b>
<b>Initial Test Document:</b> TP1.3	

#### Description

The format of the GMCID has been clarified in tissue #1846 LTMS.zip as follows

*For 'TmSrcTyp'=PTP as the value of the Grandmaster Identity as a string of non-case-sensitive hexadecimal without hyphen*

The test procedure just says "The LTMS.TmSrc = the Grandmaster clock ID"

Proposal is to replace this by:

The LTMS.TmSrc = the value of the Grandmaster Identity as a string of non-case-sensitive hexadecimal without hyphen, ....

#### History

##### #1 - 01/07/2025 08:50 AM - IEC 61850 TPWG

- Due date set to 01/21/2025
- Status changed from New to Resolved
- Assignee set to Richard Schimmel
- Triggering Tissue set to <https://iec61850.tissue-db.com/tissues/1846>

Accepted