

IEC 61850 Certificate - IEC 61850 Certificate #7086

ETICD1000

12/29/2024 09:44 AM - Herbert Falk

Status:	Approved	Certificate Name:	23-070015-02-2_ENTEC_ETICD1000_Client_Ed2_TP_1p2_Certification_KTL.pdf
Priority:	Normal	Certificate Hash:	SHA256: DED3E8C13EB97B93C829CB25114FE CDEBFCE056A7A4A730CFC22E6BE52 86742D
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Client	Vendor Artifact Hash:	
Company:	ENTEC Electric & Electronic Co.,LTD	Umbrella Organization:	
Address:	225-38 Choirubaek-ro, Bongdam-eup, Hwasung-si, Gyeonggi-do, Republic of Korea, 18329	Optional Reservation Test:	No
Product:	ETICD1000	Serial Number:	KMA8087839
HW Version:	1.0	Publisher Legacy Variants:	-
SW Version:	3.1.0	Publisher Preferred Rates:	-
Key Words:		Publisher Preferred Variants:	
Test Procedure Version:	1.2	Subscriber Legacy Variants:	-
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Control Block (9), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Rates:	-
Approval Date:	12/29/2024	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Time Activated Control:	No
Current Test Lab Name:	Korea Testing Laboratory (A)		
Test Document:	Edition 2 Client Test Procedures version 1.2		
Description			
SA ICD (Substation Automation Information Connecting Device)			

Files

23-070015-02-2_ENTEC_ETICD1000_Client_Ed2_TP_1p2_Certification_KTL.pdf	12/29/2024	Herbert Falk
--	------------	--------------