

IEC 61850 Certificate - IEC 61850 Certificate #7087

ECU-4784

12/29/2024 09:51 AM - Herbert Falk

Status:	Approved	Certificate Name:	24-059081-01-1_SANION_ECU-4784_Server_Ed2.0_Certification_KTL.pdf
Priority:	Normal	Certificate Hash:	SHA256: FA37047D11621DF840D5A66D1EF9F5 19B359D92C2BAAB26F203FEE5A70D C8F2D
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	SANION	Umbrella Organization:	
Address:	13,Geomdan-ro 114 beon-gil, Seo-gu,Incheon 22663,Rep. of KOREA	Optional Reservation Test:	No
Product:	ECU-4784	Serial Number:	KSA4107006
HW Version:	1.0	Publisher Legacy Variants:	-
SW Version:	1.0	Publisher Preferred Rates:	-
Key Words:		Publisher Preferred Variants:	
Test Procedure Version:	2.0.6	Subscriber Legacy Variants:	-
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Rates:	-
Approval Date:	12/29/2024	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Time Activated Control:	No
Current Test Lab Name:	Korea Testing Laboratory (A)		
Test Document:	Edition 2 Server Test Procedures version 2.0.6		
Description			
Related issues:			
Related to IEC 61850 Certificate - IEC 61850 Certificate #7088: ECU-4784			Approved

History

#1 - 12/29/2024 09:55 AM - Herbert Falk

- Related to IEC 61850 Certificate #7088: ECU-4784 added

Files

24-059081-01-1_SANION_ECU-4784_Server_Ed2.0_Certification_KTL1.pdf

12/29/2024

Herbert Falk