

Server - Issues #7089

sMdl4, sMdl6 and sMdl15 not possible for SV only device

12/30/2024 07:46 AM - Richard Schimmel

Status: Resolved	Due date: 01/21/2025
Priority: Normal	
Assignee: Richard Schimmel	
Category:	
Target version:	
Discuss in Upcoming Meeting: No	Updated Test Document:
Clause Reference:	Test Case ID: sMdl6, sMdl15, sMdl4
61850 Standard: 9-2	Closed Reason: --Not Set--
Triggering Tissue:	Triggering Tissue 2:
Final Decision:	Triggering Tissue 3:
Initial Test Document: TP1.3	
Description	
The mandatory sMdl4, sMdl6 and sMdl15 require an MMS server in the device under test. However for an SV only device no MMS server is available.	
Two proposals: 1) the test is passed for an SV only device 2) change to conditional "when GetDataValues is supported"	

History

#1 - 01/07/2025 08:44 AM - IEC 61850 TPWG

- Due date set to 01/21/2025

- Status changed from New to In Progress

- Assignee set to Richard Schimmel

#2 accepted

(Similar to GOOSE-only devices)

#2 - 01/21/2025 08:06 AM - IEC 61850 TPWG

- Status changed from In Progress to Resolved

Richard to add condition.