

IEC 61850 Certificate - IEC 61850 Certificate #7090

PowerLogic™ P7

12/31/2024 08:37 AM - Herbert Falk

Status:	Approved	Certificate Name:	24-4330_DNV_Schneider_P7_GoosePerformanceEd2Amd1_Certificate.pdf
Priority:	Normal	Certificate Hash:	SHA256: BFD3C3D943CCCE445F316AF8E36C9 F4B9885019A82D5CF32BBF440BC187 84675
61850 Edition:	Edition 2 Amd 1	Vendor Artifact File Name:	
61850 Tested Aspects:	GOOSE Performance	Vendor Artifact Hash:	
Company:	Schneider Electric Industries SAS	Umbrella Organization:	
Address:	35 rue Joseph Monier;92500 Rueil Malmaison: France	Optional Reservation Test:	No
Product:	PowerLogic™ P7	Serial Number:	WX221110005
HW Version:		Publisher Legacy Variants:	-
SW Version:	V01.002	Publisher Preferred Rates:	-
Key Words:		Publisher Preferred Variants:	
Test Procedure Version:	2.5	Subscriber Legacy Variants:	-
IEC 61850 Blocks Certified:	GOOSE Publish (9a), GOOSE Subscribe (9b)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Rates:	-
Approval Date:	12/31/2024	Product Variants:	
Standards Tested:	61850-8-1	Time Activated Control:	No
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:	GOOSE Performance Test Procedures version 2.5		
Description Protection and Control Device			

Files

24-4330_DNV_Schneider_P7_GoosePerformanceEd2Amd1_Certificate.pdf	101KB	12/31/2024	Herbert Falk
--	-------	------------	--------------