

IEC 61850 Certificate - IEC 61850 Certificate #7099

Current Measurement SAMU

01/13/2025 08:45 AM - Herbert Falk

Status:	Approved	Certificate Name:	24-4340_DNV_GridtoGreat_CMS_ServerEd2Amd1_Certificate.pdf
Priority:	Normal	Certificate Hash:	SHA256: E805886D3AC5488858ABA6350A686E 9BEC4D6A2F5F47CD83C90AEF6CFBE 3C7AE
61850 Edition:	Edition 2 Amd 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Merging Unit	Vendor Artifact Hash:	
Company:	Grid to Great B.V.	Umbrella Organization:	
Address:	Hengelosestraat 500 7621 AN Enschede The Netherlands	Optional Reservation Test:	No
Product:	Current Measurement SAMU	Serial Number:	
HW Version:		Publisher Legacy Variants:	F4000S1I4U4
SW Version:	1.10	Publisher Preferred Rates:	-, F14400S6, F4800S2
Key Words:		Publisher Preferred Variants:	F4800S2I4U0,F14400S6I03U0,F14400S6I4U0
Test Procedure Version:	1.2	Subscriber Legacy Variants:	-
IEC 61850 Blocks Certified:	Sampled Value Publish (11a)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Rates:	-
Approval Date:	01/13/2025	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1, 61850-9-2, 61869-9	Time Activated Control:	No
Current Test Lab Name:	DNV Netherlands (A)	Description	
Test Document:	Edition 2 Amendent 1Server Test Procedures version 1.2	Related issues:	
		Copied from IEC 61850 Certificate - IEC 61850 Certificate #7098: Voltage Meas... Approved	

History

#1 - 01/13/2025 08:45 AM - Herbert Falk

- File 24-4340_DNV_GridtoGreat_CMS_ServerEd2Amd1_Certificate.pdf added

- Copied from IEC 61850 Certificate #7098: Voltage Measurement SAMU added

Files

24-4340_DNV_GridtoGreat_CMS_ServerEd2Amd1_Certificate.pdf	100 KB	01/13/2025	Herbert Falk
---	--------	------------	--------------