

IEC 61850 Certificate - IEC 61850 Certificate #7120

IEC-61850 COMPATIBLE ANNUNCIATOR

02/01/2025 08:23 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2 Amd 1	Certificate Name: CPRI_Garden Power_CPRI BLRSGRL25TC0002_Certificate.pdf
61850 Tested Aspects:	Server	Certificate Hash: SHA256: ABABA31EAF9B9DB67048101A6B285595BC5C2DFC98D14D6B75D28C036E2AA4C4
Company:	GARDEN POWER TECHNOLOGIES PVT. LTD.	Vendor Artifact File Name:
Address:	#259/233 Shop No.1, 9th Main Road,Ideal Homes Layout, R R Nagar,Bangalore - 560098.	Vendor Artifact Hash:
Product:	IEC-61850 COMPATIBLE ANNUNCIATOR	Umbrella Organization:
HW Version:	V1.0	Optional Reservation Test: Yes
SW Version:	V1.0	Serial Number: A 24025327
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	1.2	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	02/01/2025	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	Central Power Research Institute India (A)	Product Variants:
Test Document:	Edition 2 Ammendment 1 Server Test Procedures version 1.2	Time Activated Control: No
Description The IEC 61850 Annunciator monitors and signals alarm in power systems using standardised logical nodes,real-time communication and priority-based management.		

Files

CPRI_Garden Power_CPRI BLRSGRL25TC0002_Certificate.pdf	2.74 MB	02/01/2025	Herbert Falk
--	---------	------------	--------------