

## Server - Issues #7125

### sCnf test procedures are not listed on certificates

02/07/2025 03:24 AM - Michael Haecker

<b>Status:</b> Resolved	<b>Due date:</b> 04/01/2025
<b>Priority:</b> Normal	
<b>Assignee:</b> Richard Schimmel	
<b>Category:</b>	
<b>Target version:</b>	
<b>Discuss in Upcoming Meeting:</b> No	<b>Updated Test Document:</b>
<b>Clause Reference:</b>	<b>Test Case ID:</b>
<b>61850 Standard:</b> 7-2	<b>Closed Reason:</b> --Not Set--
<b>Triggering Tissue:</b>	<b>Triggering Tissue 2:</b>
<b>Final Decision:</b>	<b>Triggering Tissue 3:</b>
<b>Initial Test Document:</b>	
<b>Description</b>	
sCnf and sDoc test procedures are not mentioned in the table 'Applicable Server Test Procedures from the UCA International Users Group Edition 2 Amendment 1 Server Test Procedures version 1.3' at the end of the document.	
sDoc TP can be considered as passed once PICS/MICS/PIXIT/TICS have been verified.	
This is to propose to add the sCnf TP to the a/m table.	

#### History

##### #1 - 02/18/2025 08:24 AM - IEC 61850 TPWG

- Due date set to 03/04/2025

Accepted. Particular concern to identify ICT Tests on the certificate. Optional/conditional sCnf and sMdl tests should be listed.

##### #2 - 02/18/2025 08:42 AM - IEC 61850 TPWG

- Status changed from New to In Progress

##### #3 - 03/04/2025 08:10 AM - IEC 61850 TPWG

- Due date changed from 03/04/2025 to 04/01/2025

3 templates to be updated.

##### #4 - 03/05/2025 02:27 AM - Richard Schimmel

- File Solution to redmine 7125 IEC 61850 Server Certificate Template with sCnf and sMdl.docx added

Attached the server certificate template TP1.3 (todo client)

##### #5 - 04/01/2025 08:34 AM - IEC 61850 TPWG

- Status changed from In Progress to Resolved

#### Files

Solution to redmine 7125 IEC 61850 Server Certificate Template with sCnf and sMdl.docx 03/05/2025 404 KB

Richard Schimmel