

Wrong enum-value "bad"

02/26/2025 04:14 AM - Markus Schicklgruber

Status:	New	Start date:	02/26/2025
Priority:	Normal	Due date:	
Assignee:		% Done:	0%
Category:			
Target version:			
Source:		TF 7-5 Project document:	IEC 61850-7-5
Category:	Not yet categorized	Related TISSUE:	
Description			
On page 17 (IEC TS 61850-7-5:2021 © IEC 2021) in middle there is the sentence			
XCBR.Pos.stVal shall be 'bad' <<			
The official enum-value for this Dbpos-state called "bad-state"			