

IEC 61850 Certificate - IEC 61850 Certificate #7155

PRS-7367 Protection and Control Unit

03/11/2025 08:54 AM - Herbert Falk

Status:	Approved	Certificate Name:	D 092391 0051_CYG_PRS-7367_IEC61850Ed2.1_Server_Certificate.pdf
Priority:	Normal	Certificate Hash:	SHA256: BFDF260FFF6E1D7CC74B48ED56CA4 421C604B0E57C039A79C7C9E36B46F E017C
61850 Edition:	Edition 2 Amd 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	CYG SUNRI CO., LTD.	Umbrella Organization:	
Address:	No. 13, Keji North 1st Road, North Area of Hi-tech Industrial Park, Nanshan District, 518057 Shenzhen, PEOPLE'S REPUBLIC OF CHINA	Optional Reservation Test:	Yes
Product:	PRS-7367 Protection and Control Unit	Serial Number:	PRS-7367-T-FAEAAT-CABEA-R1.20
HW Version:	SR7267	Publisher Legacy Variants:	-
SW Version:	V1.20	Publisher Preferred Rates:	-
Key Words:		Publisher Preferred Variants:	
Test Procedure Version:	1.2	Subscriber Legacy Variants:	-
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time sync PTP (B13b), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Rates:	-
Approval Date:	03/11/2025	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Time Activated Control:	No
Current Test Lab Name:	TUV SUD China Ltd (A)		
Test Document:	Filename: UCATestProceduresServer61850-8-1Ed2Amd1_Rev1p2.pdf		
Description PRS-7367 is a numerical distributed protection intended for protecting and monitoring various primary apparatus including overhead line, underground cable, transformer, capacitor, etc. PRS-7367 can be used in various voltage level and can detect and clear all types of internal phase to phase.			

Files

D 092391 0051_CYG_PRS-7367_IEC61850Ed2.1_Server_Certificate.pdf	204 MB	03/11/2025	Herbert Falk
---	--------	------------	--------------