

# IEC 61850 Certificate - IEC 61850 Certificate #7163

## HS-IMD

03/17/2025 07:29 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Certificate Name:</b>	25-000680-04-1_HANSHIN_HS-IMD_Server_Ed2.0_Certification_KTL.pdf
<b>Priority:</b>	Normal	<b>Certificate Hash:</b>	SHA256: 13A4F35D94BAC902C7F993B8C12D47 A065CB467C0A08F21122846079CFDE 63A9
<b>61850 Edition:</b>	Edition 2	<b>Vendor Artifact File Name:</b>	
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact Hash:</b>	
<b>Company:</b>	HANSHIN ELECTRIC Co., Ltd.	<b>Umbrella Organization:</b>	
<b>Address:</b>	42, Sanbon-ro 48beon-gil, Gunpo-si, Gyeonggi-do, Republic of Korea, 15846	<b>Optional Reservation Test:</b>	Yes
<b>Product:</b>	HS-IMD	<b>Serial Number:</b>	HS24-IMD-001
<b>HW Version:</b>	1.0	<b>Publisher Legacy Variants:</b>	-
<b>SW Version:</b>	1.0	<b>Publisher Preferred Rates:</b>	-
<b>Key Words:</b>		<b>Publisher Preferred Variants:</b>	
<b>Test Procedure Version:</b>	2.0.6	<b>Subscriber Legacy Variants:</b>	-
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1a), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), File Transfer (B14), Time sync SNTP (B13a), Unbuffered Reporting (B5)	<b>Subscriber Preferred Variants:</b>	
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Rates:</b>	-
<b>Approval Date:</b>	03/17/2025	<b>Product Variants:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	<b>Time Activated Control:</b>	No
<b>Current Test Lab Name:</b>	Korea Testing Laboratory (A)		
<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6		
<b>Description</b>			
SA Information Monitoring & diagnosis Device(SA-IMD)			
<b>Related issues:</b>			
Copied from IEC 61850 Certificate - IEC 61850 Certificate #7162: HS-IMD			<b>Approved</b>

### History

#1 - 03/17/2025 07:29 AM - Herbert Falk

- File 25-000680-04-1\_HANSHIN\_HS-IMD\_Server\_Ed2.0\_Certification\_KTL.pdf added

- Copied from IEC 61850 Certificate #7162: HS-IMD added

### Files

