

# IEC 61850 Certificate - IEC 61850 Certificate #7164

## ECU-4784

03/17/2025 07:39 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Certificate Name:</b>	24-059079-01-5_SANION_ECU-4784_Server_Ed2.1_Certification_KTL.pdf
<b>Priority:</b>	Normal	<b>Certificate Hash:</b>	SHA256: D3AA03865FE5D190D10CF81D6B3FC 4BAEBB82F3BF1FC5F751324702BD80 42763
<b>61850 Edition:</b>	Edition 2 Amd 1	<b>Vendor Artifact File Name:</b>	
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact Hash:</b>	
<b>Company:</b>	SANION	<b>Umbrella Organization:</b>	
<b>Address:</b>	13,Geomdan-ro 114 beon-gil, Seo-gu,Incheon 22663,Rep. of KOREA	<b>Optional Reservation Test:</b>	Yes
<b>Product:</b>	ECU-4784	<b>Serial Number:</b>	KSA3534414
<b>HW Version:</b>	1.0	<b>Publisher Legacy Variants:</b>	-
<b>SW Version:</b>	1.0	<b>Publisher Preferred Rates:</b>	-
<b>Key Words:</b>		<b>Publisher Preferred Variants:</b>	
<b>Test Procedure Version:</b>	1.2	<b>Subscriber Legacy Variants:</b>	-
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1a), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), Service Tracking (B15), Time sync SNTP (B13a), Unbuffered Reporting (B5)	<b>Subscriber Preferred Variants:</b>	
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Rates:</b>	-
<b>Approval Date:</b>	03/17/2025	<b>Product Variants:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	<b>Time Activated Control:</b>	No
<b>Current Test Lab Name:</b>	Korea Testing Laboratory (A)		
<b>Test Document:</b>	Edition 2 with Amendment 1 Test Procedure version 1.2		
<b>Description</b> Substation Automation Information Connecting Device			
<b>Related issues:</b> Copied to IEC 61850 Certificate - IEC 61850 Certificate #7165: ECU-4784 <span style="float: right;"><b>Approved</b></span>			

### History

#1 - 03/17/2025 07:41 AM - Herbert Falk

- Copied to IEC 61850 Certificate #7165: ECU-4784 added

### Files

