

IEC 61850 Certificate - IEC 61850 Certificate #7168

HP Z8 G4

03/17/2025 07:59 AM - Herbert Falk

Status:	Approved	Certificate Name:	24-059078-01-3_SANION_HPZ8G4_Client_Ed2.1_Certification_KTL.pdf
Priority:	Normal	Certificate Hash:	SHA256: 0143FE74A759418C3F0CE6A34F73D6 8A8467567F29926DB19E2DF5F1D8105 F20
61850 Edition:	Edition 2 Amd 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Client	Vendor Artifact Hash:	
Company:	SANION	Umbrella Organization:	
Address:	13,Geomdan-ro 114 beon-gil, Seo-gu,Incheon 22663,Rep. of KOREA	Optional Reservation Test:	Yes
Product:	HP Z8 G4	Serial Number:	
HW Version:	1.0	Publisher Legacy Variants:	-
SW Version:	1.0	Publisher Preferred Rates:	-
Key Words:		Publisher Preferred Variants:	4CE207BXQZ
Test Procedure Version:	1.0	Subscriber Legacy Variants:	-
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Control Block (9), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Rates:	-
Approval Date:	03/17/2025	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Time Activated Control:	No
Current Test Lab Name:	Korea Testing Laboratory (A)	Description	
Test Document:	Edition 2 with Amendment 1 Client Test Procedures version 1.0	Related issues:	
		Copied to IEC 61850 Certificate - IEC 61850 Certificate #7169: HP Z8 G4 Approved	

History

#1 - 03/17/2025 08:04 AM - Herbert Falk

Files

24-059078-01-3_SANION_HPZ8G4_Client_Ed2.1_Certification_KTL.pdf	31 KB	03/17/2025	Herbert Falk
---	-------	------------	--------------