

# IEC 61850 Certificate - IEC 61850 Certificate #7169

## HP Z8 G4

03/17/2025 08:04 AM - Herbert Falk

<b>Status:</b> Approved <b>Priority:</b> Normal <b>61850 Edition:</b> Edition 2 <b>61850 Tested Aspects:</b> Client <b>Company:</b> SANION <b>Address:</b> 13,Geomdan-ro 114 beon-gil, Seo-gu,Incheon 22663,Rep. of KOREA <b>Product:</b> HP Z8 G4 <b>HW Version:</b> 1.0 <b>SW Version:</b> 1.0 <b>Key Words:</b> <b>Test Procedure Version:</b> 1.2 <b>IEC 61850 Blocks Certified:</b> Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Control Block (9), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5) <b>Certificate/Result Reviewer:</b> Herbert Falk <b>Approval Date:</b> 03/17/2025 <b>Standards Tested:</b> 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1 <b>Current Test Lab Name:</b> Korea Testing Laboratory (A) <b>Test Document:</b> Edition 2 with Amendment 1 Client Test Procedures version 1.0	<b>Certificate Name:</b> 24-059078-01-2_SANION_HPZ8G4_Client_Ed2.0_Certificate_KTL.pdf <b>Certificate Hash:</b> SHA256: A175A9C0A3F45C33A40DDE709C72E2 BCE1D1483122B9CF83A5CD3465806C BB08 <b>Vendor Artifact File Name:</b> <b>Vendor Artifact Hash:</b> <b>Umbrella Organization:</b> <b>Optional Reservation Test:</b> Yes <b>Serial Number:</b> <b>Publisher Legacy Variants:</b> - <b>Publisher Preferred Rates:</b> - <b>Publisher Preferred Variants:</b> 4CE207BXQZ <b>Subscriber Legacy Variants:</b> - <b>Subscriber Preferred Variants:</b> <b>Subscriber Preferred Rates:</b> - <b>Product Variants:</b> <b>Time Activated Control:</b> No
<b>Description</b>	
<b>Related issues:</b>	
Copied from IEC 61850 Certificate - IEC 61850 Certificate #7168: HP Z8 G4 <span style="float: right;"><b>Approved</b></span>	

### History

#1 - 03/17/2025 08:04 AM - Herbert Falk

- File 24-059078-01-2\_SANION\_HPZ8G4\_Client\_Ed2.0\_Certificate\_KTL.pdf added

- Copied from IEC 61850 Certificate #7168: HP Z8 G4 added

**Files**

---

24-059078-01-2_SANION_HPZ8G4_Client_Ed2.0_Certificate_KTL.pdf 126 KB	03/17/2025	Herbert Falk
--	------------	--------------