

IEC 61850 Certificate - IEC 61850 Certificate #7175

REC670 (with variants)

03/31/2025 08:56 AM - Herbert Falk

<p>Status: Approved</p> <p>Priority: Normal</p> <p>61850 Edition: Edition 2</p> <p>61850 Tested Aspects: Server</p> <p>Company: HITACHI Energy Sweden AB</p> <p>Address: GA Products S-721 59 Västerås Sweden</p> <p>Product: REC670</p> <p>HW Version: 2.2.7</p> <p>SW Version: 2.2.22.1</p> <p>Key Words:</p> <p>Test Procedure Version: 2.0.6</p> <p>IEC 61850 Blocks Certified: Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time sync PTP (B13b), Time sync SNTP (B13a), Unbuffered Reporting (B5)</p> <p>Certificate/Result Reviewer: Herbert Falk</p> <p>Approval Date: 03/31/2025</p> <p>Standards Tested: 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1, 61850-9-2</p> <p>Current Test Lab Name: DNV Netherlands (A)</p> <p>Test Document: Edition 2 Server Test Procedures version 2.0.6</p>	<p>Certificate Name: 25-2420_DNV_HITACHI_REC670_ServerEd2_Certificate.pdf</p> <p>Certificate Hash: SHA256: 56CCC366A87EFED96FA6FD47935933 496253B67B2B488E3223C5F12FCFA1 53CE</p> <p>Vendor Artifact File Name:</p> <p>Vendor Artifact Hash:</p> <p>Umbrella Organization:</p> <p>Optional Reservation Test: Yes</p> <p>Serial Number:</p> <p>Publisher Legacy Variants: -</p> <p>Publisher Preferred Rates: -</p> <p>Publisher Preferred Variants:</p> <p>Subscriber Legacy Variants: -</p> <p>Subscriber Preferred Variants:</p> <p>Subscriber Preferred Rates: -</p> <p>Product Variants: RET670, RED670,RER670,RES670, REB670, REG670,REL670</p> <p>Time Activated Control: No</p>
<p>Description Bay Control</p>	
<p>Related issues: Copied from IEC 61850 Certificate - IEC 61850 Certificate #7174: REC670 (wi... Approved</p>	

History

#1 - 03/31/2025 08:56 AM - Herbert Falk

- File 25-2420_DNV_HITACHI_REC670_ServerEd2_Certificate.pdf added
- Copied from IEC 61850 Certificate #7174: REC670 (with variants) added

#2 - 03/31/2025 08:58 AM - Herbert Falk

- Standards Tested 61850-9-2 added

#3 - 04/02/2025 10:43 AM - Herbert Falk

- IEC 61850 Blocks Certified deleted (Sampled Value Subscribe (11b))
- Subscriber Legacy Variants - added
- Subscriber Legacy Variants deleted (F4000S114U4, F4800S114U4)
- Subscriber Preferred Rates - added
- Subscriber Preferred Rates deleted (F4800S2)

Files

25-2420_DNV_HITACHI_REC670_ServerEd2_Certificate.pdf	107 KB	03/31/2025	Herbert Falk
--	--------	------------	--------------