

IEC 61850 Certificate - IEC 61850 Certificate #7186

PCS-9700 HMI System

04/26/2025 10:22 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2 Amd 1	Certificate Name: D 061589 0212_NREC_PCS-9700_IEC61850Ed2.1_Client_Certificate.pdf
61850 Tested Aspects:	Server	Certificate Hash: SHA256: F1217402E033B2E3D6E6EC0CF66855 1131A5AD1C521566FB4EC9BE31CC34 165D
Company:	NR Electric Co., Ltd.	Vendor Artifact File Name:
Address:	69 Suyuan Avenue, Jiangning, 211102 Nanjing, PEOPLE'S REPUBLIC OF CHINA	Vendor Artifact Hash:
Product:	PCS-9700 HMI System	Umbrella Organization:
HW Version:	Inspur NE5260H6	Optional Reservation Test: Yes
SW Version:	3.0	Serial Number: NRJB2000002413940
Key Words:	HMI	Publisher Legacy Variants: -
Test Procedure Version:	1.0	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), Logging (B7), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	04/26/2025	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	TUV SUD China Ltd (A)	Product Variants:
Test Document:	Edition 2 with Amendment 1 Client Test Procedure version 1.0	Time Activated Control: No
Description PCS-9700 HMI System integrates Advanced distributed network technology, object-oriented database technology and cross-platform visualization technology.		

History

#1 - 04/27/2025 07:38 AM - Herbert Falk

- File D 061589 0212_NREC_PCS-9700_IEC61850Ed2.1_Client_Certificate.pdf added

Files

