

IEC 61850 Certificate - IEC 61850 Certificate #7187

DF1331 Remote Terminal Unit

04/26/2025 10:35 AM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2 Amd 1	Certificate Name:	D 093550 0001_DongFang_DF1331_IEC61850Ed 2.1_Client_Certificate.pdf
61850 Tested Aspects:	Server	Certificate Hash:	SHA256: 3CF7E3C3DB372E9C8D7D82F2314616 D98DD68C6870ACFA6E982D044A26B D405F
Company:	Dongfang Electronics Co., Ltd.	Vendor Artifact File Name:	
Address:	"2 JiChang Road 264000 Yantai, Shangdong Province PEOPLE'S REPUBLIC OF CHINA"	Vendor Artifact Hash:	
Product:	DF1331 Remote Terminal Unit	Umbrella Organization:	
HW Version:	DF1331 V1.1	Optional Reservation Test:	Yes
SW Version:	1331MCB-V4.00	Serial Number:	20240123
Key Words:	RTU	Publisher Legacy Variants:	-
Test Procedure Version:	1.0	Publisher Preferred Rates:	-
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Publisher Preferred Variants:	
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants:	-
Approval Date:	04/26/2025	Subscriber Preferred Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:	-
Current Test Lab Name:	TUV SUD China Ltd (A)	Product Variants:	
Test Document:	Edition 2 with Amendment 1 Client Test Procedure version 1.0	Time Activated Control:	No
Description The product DF1331 Remote Terminal Unit has Advanced network communication technique, Real distributed electrical structure design with high stability, Convenient remote and local maintenance functions, Support mixed kinds of analog sampling, High capacity CPU, Sub-master capability, Interface to intelligent electronic devices (IEDs), Communication through radio medium and Self-contained alarm message.			

Files

D 093550 0001_DongFang_DF1331_IEC61850Ed2.1_Client_Certificate.pdf	224KB	04/26/2025	Herbert Falk
--	-------	------------	--------------