

IEC 61850 Certificate - IEC 61850 Certificate #7191

SA-ICD

05/04/2025 08:50 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2 Amd 1	Certificate Name: 25-000679-01-3_HanShin_HS-ICD_Ed.2 .1_Client_Certification_KTL.pdf
61850 Tested Aspects:	Client	Certificate Hash: SHA256: 62A31FDA4BB07F4704827FA537AA84 717F7AE59F406A70ABBE6EA57B34E 04D8
Company:	HanShin	Vendor Artifact File Name:
Address:	42, Sanbon-ro 48beon-gil, Gunpo-si, Gyeonggi-do, Republic of Korea, 15846	Vendor Artifact Hash:
Product:	SA-ICD	Umbrella Organization:
HW Version:	1.0/ADVANTECH ECU-4784	Optional Reservation Test: Yes
SW Version:	1.0	Serial Number: HS24-ICD-001
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	1.0	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Control Block (9), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	05/04/2025	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	Korea Testing Laboratory (A)	Product Variants:
Test Document:	Edition 2 with Amendment 1 Client Test Procedures version 1.0	Time Activated Control: No
Description Substation Automation Information Connecting Device		
Related issues: Copied to IEC 61850 Certificate - IEC 61850 Certificate #7192: SA-ICD Approved		

History

- #1 - 05/04/2025 08:54 AM - Herbert Falk
- Copied to IEC 61850 Certificate #7192: SA-ICD added

Files

25-000679-01-3_HanShin_HS-ICD_Ed.2.1_Client_Certification_KTL.pdf	23 KB	05/04/2025	Herbert Falk
---	-------	------------	--------------