

IEC 61850 Certificate - IEC 61850 Certificate #7194

SA-OPD

05/04/2025 09:02 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 25-000678-01-2_HanShin_HS-OPD_Ed.2.0_Client_Certification_KTL.pdf
61850 Tested Aspects:	Client	Certificate Hash: SHA256: 5CA8273F798BC085A61F77EE9116EE CB1248C589A16A40CE9D3C15CCCF2 B68D7
Company:	HanShin	Vendor Artifact File Name:
Address:	42, Sanbon-ro 48beon-gil, Gunpo-si, Gyeonggi-do, Republic of Korea, 15846	Vendor Artifact Hash:
Product:	SA-OPD	Umbrella Organization:
HW Version:	1.0	Optional Reservation Test: Yes
SW Version:	1.0/Windows Server 2019	Serial Number: HS24-OPD-001
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	1.0	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Control Block (9), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	05/04/2025	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	Korea Testing Laboratory (A)	Product Variants:
Test Document:	Edition 2 with Amendment 1 Client Test Procedures version 1.0	Time Activated Control: No
Description		
Related issues: Copied from IEC 61850 Certificate - IEC 61850 Certificate #7193: SA-OPD Approved		

History

- #1 - 05/04/2025 09:02 AM - Herbert Falk
- File 25-000678-01-2_HanShin_HS-OPD_Ed.2.0_Client_Certification_KTL.pdf added
 - Copied from IEC 61850 Certificate #7193: SA-OPD added

Files

25-000678-01-2_HanShin_HS-OPD_Ed.2.0_Client_Certification_KTL.pdf	120 KB	05/04/2025	Herbert Falk
---	--------	------------	--------------