

IEC 61850 Certificate - IEC 61850 Certificate #7196

HS-ICD

05/04/2025 09:10 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 25-000679-01-5_HanShin_HS-ICD_Ed.2 .1_Server_Certification_KTL.pdf
61850 Tested Aspects:	Server	Certificate Hash: SHA256: 667524C81D6AA90D10914C72CF019A BA2691D104552D5C7E70CC5CF4FD0 7D4F5
Company:	HANSHIN ELECTRIC Co., Ltd.	Vendor Artifact File Name:
Address:	42, Sanbon-ro 48beon-gil, Gunpo-si, Gyeonggi-do, Republic of Korea, 15846	Vendor Artifact Hash:
Product:	HS-ICD	Umbrella Organization:
HW Version:	1.0	Optional Reservation Test: Yes
SW Version:	1.0	Serial Number: HS24-ICD-001
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	2.0.6	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), Service Tracking (B15), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	05/04/2025	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	Korea Testing Laboratory (A)	Product Variants:
Test Document:	Edition 2 Server Test Procedures 2.0.6	Time Activated Control: No
Description SA Information Connecting Device(SA-ICD)		
Related issues: Copied from IEC 61850 Certificate - IEC 61850 Certificate #7195: HS-ICD Approved		

History

- #1 - 05/04/2025 09:10 AM - Herbert Falk
- File 25-000679-01-4_HanShin_HS-ICD_Ed.2.0_Server_Certification_KTL.pdf added
 - Copied from IEC 61850 Certificate #7195: HS-ICD added

Files

25-000679-01-4_HanShin_HS-ICD_Ed.2.0_Server_Certification_KTL.pdf	156 KB	05/04/2025	Herbert Falk
---	--------	------------	--------------