

IEC 61850 User Feedback Task Force - Improvement #7197

Inconsistency of DO in LN SARC

05/05/2025 07:06 AM - Christophe Ghafari

Status:	New	Start date:	05/05/2025
Priority:	Normal	Due date:	
Assignee:		% Done:	0%
Category:		Estimated time:	0.00 hour
Target version:			
ID:		To discuss in WG10:	No
Source:		Short Proposal:	
TF Unique ID:		Standard(s):	IEC 61850-7-4
WG10 Proposal:		Needs More Information:	No
Estimated Completion:		Assigned TF:	None
Discuss in Upcoming Meeting:	Yes		

Description

Today, in LN SARC, there is FADet and SwArcDet. Based on the dictionnary, A is for current. For this reason FADet should be renamed in FArcDet to be consistent.
Same reasoning for FACntRs, which should be FArcCntRs.

Proposal descriptions

FADet should be renamed in FArcDet to be consistent.
Same reasoning for FACntRs, which should be FArcCntRs.