

IEC 61850 User Feedback Task Force - Improvement #7198

SwgTmms semantic not meaningful

05/05/2025 07:15 AM - Christophe Ghafari

Status:	New	Start date:	05/05/2025
Priority:	Normal	Due date:	
Assignee:		% Done:	0%
Category:		Estimated time:	0.00 hour
Target version:			
ID:		To discuss in WG10:	No
Source:		Short Proposal:	
TF Unique ID:		Standard(s):	IEC 61850-7-4
WG10 Proposal:		Needs More Information:	No
Estimated Completion:		Assigned TF:	None
Discuss in Upcoming Meeting:	Yes		

Description

In LN RPSB, the semantic of "SwgTmms" does not properly reflect that this is a time window. There is a possible risk of confusion with "instant of power swing detection".

Proposal descriptions

Like DO EvTmms, it is proposed to change the semantic to "Power Swing detection time window".