

IEC 61850 User Feedback Task Force - Improvement #7199

Addition of a DO representing the acoustic noise

05/05/2025 07:27 AM - Christophe Ghafari

Status:	New	Start date:	05/05/2025
Priority:	Normal	Due date:	
Assignee:		% Done:	0%
Category:		Estimated time:	0.00 hour
Target version:			
ID:		To discuss in WG10:	No
Source:		Short Proposal:	
TF Unique ID:		Standard(s):	IEC 61850-7-4
WG10 Proposal:		Needs More Information:	No
Estimated Completion:		Assigned TF:	None
Discuss in Upcoming Meeting:	Yes		

Description

Add a new DO for Measured Value and an other DO for Alarm and its corresponding threshold.

Use case: monitoring of transformer and reactance noise for maintenance.

Proposal descriptions

Could be included in logical node MMET.