

Server - Issues #7235

sMdl18 is dchg="true" mandatory for for example ctlModel

06/12/2025 06:59 AM - Richard Schimmel

Status: New	Due date:
Priority: Normal	
Assignee:	
Category:	
Target version:	
Discuss in Upcoming Meeting: No	Updated Test Document:
Clause Reference: Part 6 Table 47	Test Case ID:
61850 Standard: 6	Closed Reason: --Not Set--
Triggering Tissue:	Triggering Tissue 2:
Final Decision:	Triggering Tissue 3:
Initial Test Document:	

Description

Part 7-3 states that in case of dchg and dupd the SCL shall select one.
But for for example ctlModel which has only trgop dchg in part 7-3.
Shall ctlModel have trgop:
1) dchg="true"?
2) dchg="false" also allowed?
3) dchg missing also allowed (the default value in the schema is false)

The ctlModel is readonly and will not be changed internally. So there will never be a data change.

Part 6 Table 47 states: *Defines which trigger option is supported by the attribute (value true means supported). One of those allowed according to IEC61850-7-3 shall be chosen. *