

IEC 61850 Certificate - IEC 61850 Certificate #7238

SD DAU V1

06/19/2025 07:09 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2 Amd 1	Certificate Name: 25-018975-01-2_LS ELECTRIC_SD DAU V1_Ed.2.1_Server_Certification_KTL.pdf
61850 Tested Aspects:	Server	Certificate Hash: SHA256: DF69AEA369E85A91C5724791A9782E E2CF0194C2148C37287636A3E47ED9 63B3
Company:	LS ELECTRIC	Vendor Artifact File Name:
Address:	127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do, Republic of Korea	Vendor Artifact Hash:
Product:	SD DAU V1	Umbrella Organization:
HW Version:	1.0	Optional Reservation Test: Yes
SW Version:	1.0	Serial Number: 25E30443730001
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	1.3	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	06/19/2025	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	Korea Testing Laboratory (A)	Product Variants:
Test Document:	Edition 2 with Amendment 1 Server Test Procedures version 1.3	Time Activated Control: No
Description		

Files

25-018975-01-2_LS ELECTRIC_SD DAU V1_Ed.2.1_Server_Certification_KTL.pdf	06/19/2025	Herbert Falk
--	------------	--------------