

IEC 61850 Certificate - IEC 61850 Certificate #7269

GHSA-IMD

07/18/2025 07:34 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 25-035857-01-1_GENAD_GHSA-IMD_Server_Ed2.0_Certification_KTL.pdf
61850 Tested Aspects:	Server	Certificate Hash: SHA256: 06967F2ECB124D06D91CF9BBA6B5D 13D7EA8E893058648F28B2EDDBE759 78DD0
Company:	GENAD SYSTEM Co., Ltd.	Vendor Artifact File Name:
Address:	78, Hyeoksinsandan 5 gil, Naju-si, Jeollanam-do	Vendor Artifact Hash:
Product:	GHSA-IMD	Umbrella Organization:
HW Version:	1.0	Optional Reservation Test: Yes
SW Version:	1.0	Serial Number: IMD-25-001
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	2.0.6	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	07/18/2025	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	Korea Testing Laboratory (A)	Product Variants:
Test Document:	Edition 2 Server Test Procedures version 2.0.6	Time Activated Control: No
Description SA Information Monitoring & Diagnosis Device		
Related issues: Copied to IEC 61850 Certificate - IEC 61850 Certificate #7270: GHSA-IMD Approved		

History

#1 - 07/18/2025 07:38 AM - Herbert Falk
- Copied to IEC 61850 Certificate #7270: GHSA-IMD added

Files

25-035857-01-1_GENAD_GHSA-IMD_Server_Ed2.0_Certification_KTL.pdf	101KB	07/18/2025	Herbert Falk
--	-------	------------	--------------