

IEC 61850 Certificate - IEC 61850 Certificate #7273

BP-2CD Busbar Protection

07/21/2025 07:37 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2 Amd 1	Certificate Name: D 092391 0058_CYG_BP-2CD_IEC61850Ed2.1_Server_Certificate.pdf
61850 Tested Aspects:	Server	Certificate Hash: 8EB8BEA9DA3D288899356573C95CD2 14FE007031C5278F050C800A69D8B658CA
Company:	CYG SUNRI CO., LTD.	Vendor Artifact File Name:
Address:	No. 13, Keji North 1st Road, North Area of Hi-tech Industrial Park, Nanshan District, 518057 Shenzhen, PEOPLE'S REPUBLIC OF CHINA	Vendor Artifact Hash:
Product:	BP-2CD Busbar Protection	Umbrella Organization:
HW Version:	SR7260	Optional Reservation Test: Yes
SW Version:	V2.03	Serial Number: CYSR3020000000218493
Key Words:	Relay	Publisher Legacy Variants: -
Test Procedure Version:	1.2	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time sync PTP (B13b), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	07/21/2025	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	TUV SUD China Ltd (A)	Product Variants:
Test Document:	Edition 2 with Amendment 1 Server Test Procedures version 1.2	Time Activated Control: No
Description Busbar Protection		

History

#1 - 07/26/2025 07:20 AM - Herbert Falk

- Serial Number changed from V2.03 to CYSR3020000000218493

Files

D 092391 0058_CYG_BP-2CD_IEC61850Ed2.1_Server_Certificate.pdf	1.42 MB	07/21/2025	Herbert Falk
---	---------	------------	--------------