

IEC 61850 Certificate - IEC 61850 Certificate #7281

PRS-7395 Merging and Control Unit

07/21/2025 12:25 PM - Herbert Falk

Status:	Approved	Certificate Name:	D 092391 0060_CYG_PRS-7395_IEC61850Ed2.1_Server_Certificate.pdf
Priority:	Normal	Certificate Hash:	SHA256: EC273DD1125A546A4A6E93F72A40DB 32625E3AC3A52D11E6026E0BE22203 CAEA
61850 Edition:	Edition 2 Amd 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	CYG SUNRI CO., LTD.	Umbrella Organization:	
Address:	No. 13, Keji North 1st Road, North Area of Hi-tech Industrial Park, Nanshan District, 518057 Shenzhen, PEOPLE'S REPUBLIC OF CHINA	Optional Reservation Test:	No
Product:	PRS-7395 Merging and Control Unit	Serial Number:	CYSR3020000001072602
HW Version:	SR7260	Publisher Legacy Variants:	F12800S8I4U4, F4000S114U4, F4800S114U4
SW Version:	V2.03	Publisher Preferred Rates:	none
Key Words:	Merging Unit	Publisher Preferred Variants:	F14400S6I4U4
Test Procedure Version:	1.2	Subscriber Legacy Variants:	none
IEC 61850 Blocks Certified:	GOOSE Publish (9a), GOOSE Subscribe (9b), Sampled Value Publish (11a), Time sync PTP (B13b), Time sync SNTP (B13a)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Rates:	none
Approval Date:	07/21/2025	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1, 61850-9-2, 61869-9	Time Activated Control:	No
Current Test Lab Name:	TUV SUD China Ltd (A)		
Test Document:	Edition 2 with Amendment 1 Server Test Procedures version 1.2		
Description The PRS-7973 multifunction fault recorder is mainly used for recording the dynamic fault processes of power system anomalies. It is mainly designed to capture and diagnose the changing process of relative electrical parameters of the power system.			

History

#1 - 07/26/2025 07:37 AM - Herbert Falk

- File D 092391 0060_CYG_PRS-7395_IEC61850Ed2.1_Server_Certificate.pdf added
- Publisher Preferred Variants set to F14400S6I4U4
- Product Variants deleted (F800S2I0-4U0-4)
- Publisher Preferred Rates none added

- Publisher Preferred Rates deleted (-)

#2 - 07/29/2025 06:59 AM - Herbert Falk

- Standards Tested 61850-9-2 added

Files

D 092391 0060_CYG_PRS-7395_IEC61850Ed2.1_Server_Certificate.pdf	2.12 MB	07/26/2025	Herbert Falk
---	---------	------------	--------------