

Server - Issues #7288

TISSUE 1937 GTS has been extended in 8-1, but the SNSD does not expose the extension.

07/29/2025 07:22 AM - IEC 61850 TPWG

Status:	In Progress	Due date:	08/19/2025
Priority:	Normal		
Assignee:	Richard Schimmel		
Category:			
Target version:			
Discuss in Upcoming Meeting:	No	Updated Test Document:	
Clause Reference:		Test Case ID:	Tracking GoCB
61850 Standard:		Closed Reason:	--Not Set--
Triggering Tissue:	1937	Triggering Tissue 2:	
Final Decision:		Triggering Tissue 3:	
Initial Test Document:			
Description			

History

#1 - 08/01/2025 06:31 AM - Richard Schimmel

- Status changed from New to In Progress
- Triggering Tissue set to 1937
- Test Case ID set to Tracking GoCB

The cdc="GTS" was missing the optional: minTime, maxTime and fixedOffs. This may impact sMdl7 and sMdl15. The GTS minTime, maxTime and fixedOffs were already allowed and it's nice to have these in the 8-1 NSD. No impact on the test procedures.