

Server - Issues #7293

CF, SP, SE/SG attributes shall have a <Val> in the ICD file.

08/04/2025 04:37 AM - Thierry Dufaure

Status: New	Due date:
Priority: Normal	
Assignee:	
Category:	
Target version:	
Discuss in Upcoming Meeting: No	Updated Test Document:
Clause Reference:	Test Case ID:
61850 Standard: 6, 7-2	Closed Reason: --Not Set--
Triggering Tissue: 1983	Triggering Tissue 2:
Final Decision:	Triggering Tissue 3:
Initial Test Document:	

Description

sSrv16 or redmine 6518
does verify the coherency of the values exposed in the device and SCL.
Indirectly, this means that the each CF, SP, SG/SE shall have a value exposed in SCL, does it not?
Tissue <https://iec61850.tissue-db.com/tissues/1983> - propose to have a dedicated test. Is it necessary or do we have it already with sSrv16 indirectly?